

PH・MMA廃棄物焼却炉運転温度(炉内、廃熱ボイラー出口)

2018年 1月度

日	PH廃棄物焼却炉			MMA廃棄物焼却炉		
	炉内温度 ℃	ボイラー出口温度 ℃	備考	炉内温度 ℃	ボイラー出口温度 ℃	備考
1	921	216		870	165	
2	922	216		873	165	
3	919	216		881	165	
4	914	215		883	165	
5	913	215		883	165	
6	915	215		881	165	
7	915	214		884	165	
8	915	214		884	165	
9	909	213		880	166	
10	907	213		881	166	
11	908	213		884	167	
12	910	212		883	167	
13	912	213		871	167	
14	912	214		862	167	
15	914	214		883	166	
16	917	215		871	164	
17	919	215				計画停止
18	917	217				↓
19	920	218				
20	920	217				
21	919	216				
22	922	216				
23	915	216		875	157	
24	916	214		859	161	
25	919	215		904	174	
26	912	214		952	173	
27	909	212		873	174	
28	913	208		858	171	
29	912	206		877	172	
30	917	203		885	171	
31	921	202		873	171	