

PH・MMA廃棄物焼却炉運転温度(炉内、廃熱ボイラー出口)

2022 年 2 月度

日	PH廃棄物焼却炉			MMA廃棄物焼却炉		
	炉内温度 ℃	ボイラー出口温度 ℃	備考	炉内温度 ℃	ボイラー出口温度 ℃	備考
1	904	203		847	171	
2	910	203		845	172	
3	910	203		851	170	
4	908	203		848	171	
5	912	203		860	169	
6	911	204		858	171	
7	909	203		849	170	
8	918	201		856	171	
9	920	196		856	169	
10	923	192		868	170	
11	909	198		851	169	
12	905	199		845	170	
13	908	199		848	169	
14	912	201		849	169	
15	915	201		858	165	
16	911	200		875	169	
17	908	198		868	170	
18	910	198		896	171	
19	912	196		858	170	
20	916	194		856	172	
21	916	194		867	171	
22	911	194		866	171	
23	913	193		868	169	
24	911	193		862	171	
25	910	198		853	170	
26	915	200		858	170	
27	916	201		856	168	
28	918	202		858	169	