

PH・MMA廃棄物焼却炉運転温度(炉内、廃熱ボイラー出口)

2019 年 02 月度

日	PH廃棄物焼却炉			MMA廃棄物焼却炉		
	炉内温度 ℃	ボイラー出口温度 ℃	備考	炉内温度 ℃	ボイラー出口温度 ℃	備考
1	888	193		874	167	
2	893	194		878	167	
3	890	195		879	167	
4	888	196		880	168	
5	901	198		875	168	
6	908	194		866	168	
7	912	196		862	168	
8	905	198		863	168	
9	888	199		868	168	
10	884	198		871	168	
11	898	198		869	168	
12	897	198		863	168	
13	892	200		874	168	
14	887	199		881	168	
15	887	199		880	168	
16	887	199		863	168	
17	885	199		865	168	
18	891	199		864	169	
19	898	199		864	169	
20	896	200		855	169	
21	890	202		867	168	
22	891	202		879	168	
23	896	201		880	168	
24	897	199		864	169	
25	906	197		864	169	
26	914	194		881	169	
27	899	195		890	168	
28	904	194		878	168	
29						
30						
31						